



Jim Doyle, Governor Mary P. Burke, Secretary

June 22, 2007

INFILTRATOR SYSTEMS INC. DAVID LENTZ 6 BUSINESS PARK RD. PO BOX 768 OLD SAYBROOK CT 06475

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS

Manufacturer: INFILTRATOR SYSTEMS INC.

Product Name: REMEDIATOR Model Number(s): REMEDIATOR Product File No: 20070262

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2012.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this
 product approval. If there is a conflict between the manufacturer's installation instructions and the product
 approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table Comm 83.44-3. Wis. Adm. Code.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.
- This product must be maintained at least annually.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 07026201.DOC